


Sanitary Sewer Condition

Asset	Length (Feet)	Percentage of Total Pipes
Sanitary Sewer Pipes (Total System)	253,731	100%
Sanitary Sewer Pipes (< 20 years old)	73,200	28.8%
Inspected Sanitary Sewer Pipes*	64,295	25.3%

Structural Quick Codes	Inspected Length (Feet)	Percentage of Inspected Pipes
Quick Code: 0 (No Defects)	13,320	20.7%
Quick Code: 1 (Very Good)	2,921	4.5%
Quick Code: 2 (Good)	9,656	15.0%
Quick Code: 3 (Fair)	20,884	32.5%
Quick Code: 4 (Poor)	8,323	13.0%
Quick Code: 5 (Very Poor)	9,191	14.3%
Totals	64,295	100.0%

*Inspection data through February 23, 2017



St. Joseph SAW Grant Public Information Meeting No. 1



Condition Assessment: Sanitary Sewer

Structural Quick Code:

- No Defects
- Very Good
- Good
- Fair
- Poor
- Very Poor

Base Data:

- City Limits

April 22, 2017

0 1,000 2,000 Feet

