


Storm Sewer Condition

Asset	Length (Feet)	Percentage of Total Pipes
Storm Sewer Pipes (Total System)	181,271	100%
Storm Sewer Pipes (< 20 years old)	79,624	43.9%
Inspected Storm Sewer Pipes*	12,295	6.8%

Structural Quick Codes	Inspected Length (Feet)	Percentage of Inspected Pipes
Quick Code: 0 (No Defects)	4,452	36.2%
Quick Code: 1 (Very Good)	3,018	24.5%
Quick Code: 2 (Good)	1,261	10.3%
Quick Code: 3 (Fair)	1,576	12.8%
Quick Code: 4 (Poor)	1,149	9.4%
Quick Code: 5 (Very Poor)	838	6.8%
Totals	12,295	100.0%

*Inspection data through February 23, 2017



St. Joseph SAW Grant Public Information Meeting No. 1



Condition Assessment: Storm Sewer

Structural Quick Code:

- No Defects
- Very Good
- Good
- Fair
- Poor
- Very Poor

Base Data:

- City Limits

April 22, 2017

0 1,000 2,000
Feet

